


EU Declaration of Conformity

Product:		<i>Solid State Flow Switches</i>
Name and address of the manufacturer:		Name and address of the authorised representative:
Rockwell Automation Inc.		Rockwell Automation NV
1201 South 2nd Street		Pegasus Park
Milwaukee, WI 53204		De Kleetlaan 12A
U.S.A.		1831 Diegem
		Belgium
<i>This declaration of conformity is issued under the sole responsibility of the manufacturer.</i>		
Object of the declaration:	<i>Allen-Bradley 839E Series</i>	
	<i>(reference the attached list of catalogue numbers)</i>	
<i>The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:</i>		
2014/35/EU	Low Voltage Directive	(LVD)
2011/65/EU	RoHS Directive	(RoHS)
<i>References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:</i>		
<i>EN 61326-1:2013</i>	<i>Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements</i>	
<i>EN 61326-2-3:2013</i>	<i>Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 2-3: Particular requirements – Test configuration, operational conditions and performance criteria for transducers with integrated or remote signal conditioning</i>	
<i>EN 63000:2018</i>	<i>Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances</i>	
<i>Signed for and on behalf of the above named manufacturer:</i>		
<i>Place and date of issue:</i>	<i>Milwaukee, WI USA</i>	<i>21-Sep-2021</i>
<i>Name, function:</i>	<i>Daniel L. Nachtigall, Technical Leader – Product Compliance Engineering</i>	
<i>Signature:</i>		

<i>Catalogue number</i>	<i>Series ¹</i>	<i>Description</i>
839E-xBAxxD4		<i>Solid state flow switches per Nomenclature</i>

1) Products of the series level indicated, as well as succeeding series levels, are certified. If no series letter or number is given, then all series are certified.

NOMENCLATURE:

839E

839E-D	A1	BA	1	A3	D4
1	2	3	4	5	6

1	Designates Product Type 839E-D – Solid state condition sensing flow switch with digital display
2	Designates Supply Voltage and Output Type A1 – 12...30V DC with dual PNP output C1 – 12...30 V DC with 4-20 mA analogue output and single PNP output
3	Designates Flow Range BA – 0.03...3 meters/sec
4	Designates Process Connection Type 1 – 1/4-inch NPT (male) 2 – 1/2-inch NPT (male) 3 – G1/4 GSPP (male) 4 – G1/2 GSPP (male) 7 – Base switch (no adapter) B – 1...1-1/2-inch sanitary clamp C – 2-inch sanitary clamp
5	Designates Flow Probe Length A3 – 30mm A2 – 100mm
6	Designates Termination Type D4 – M12 micro connector